

## FIRE SAFETY CERTIFICATE

No. 518740002024

Dated : 03.06.2024

Certified that the **Navyabharathi Educational Society** at **Manikbhandar(V), Makloor(M), Nizamabad Dist** comprised of **Zero** basement(s) and **Ground + 3 floors** (upper floors) occupied by **Navyabharathi Global School** have complied with the fire prevention and fire safety requirements in accordance with rule of State/ UT Fire Service Rules, and verified by the officers concerned of Fire Service on **09/03/2024** (date of inspection) in the presence of **K. Santhosh Kumar plot no: 408, Navyasri Homes, armur Road, Nizamabad** and that the building/ premises is fit for occupancy upto classes **XII** With effect from **09.03.2024** for a period of **Five** years in accordance with rule and subject to compliance of specific conditions as appended:-

- 1.
- 2.
- 3.
- 4.

Issued on 09.03.2024 at **Nizamabad** by

Signature with Seal: .....  
 Name : ..**G. Murall. Madhwar. Reddy**.....  
 Designation : ..... **District. Fire. Officer**.....  
 Name & Address of Department/Office: **Nizamabad: Division**.....


To  
**Navyabharathi Educational Society**  
**H.No 4.167,**  
**Manikbhandar(V), Makloor(M),**  
**Nizamabad Dist**

## ENDORSEMENT


The No Objection Certificate issued by Fire Service stand cancelled an annulled due to  
 .....  
 (reasons to be recorded).

(Name and designation of the authorized signatory)

  
**Correspondent**  
**Navyabharathi Global School**  
**Dasnagar, Nizamabad.**

  
**PRINCIPAL**  
**NAVYABHARATHI GLOBAL SCHOOL**  
**CBSE SENIOR SECONDARY SCHOOL**  
**AFFL. No. 3630071, SCHOOL No.: 57590**  
**NIZAMABAD-503003 (T.G), INDIA.**





**GOVERNMENT OF TELANGANA  
STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT**



From: The District fire officer,  
Nizamabad Division.

To: KYATHAM SANTHOSH KUMAR,  
plot no: 408,  
navyasri homes,  
armur road,  
Nizamabad.,

Ack. No.518740002024 Dated:09/03/2024

Sir,  
Sub: TELANGANA STATE DISASTER  
RESPONSE & FIRE SERVICE  
DEPARTMENT –Nizamabad Division.  
Renewal of No Objection Certificate for  
Occupancy to the Non Multi storeyed Building  
of NAVYABHARATHI EDUCATIONAL  
SOCIETY,,Bearing in H.NO: 4-167,  
SURVEY NO:189, Situated at MANIK  
BHANDAR (V), MAKLOOR(M),  
NIZAMABAD Dist./-Manik  
Bhandar/Makloor/Nizamabad , – Regarding.



Ref: 1. Acknowledgement No 518740002024  
2. This Office NOC for Occupancy Ack/RC No.310450002019 dt.09/03/2024  
3. Non Multi storeyed Building Inspection Committee Report.,  
Ack. No. 518740002024, dt. 09/03/2024

\*\*\*\*\*

- The Non Multi storeyed Building Inspection committee, vide reference cited (3) has inspected the Non Multi storeyed Building of NAVYABHARATHI EDUCATIONAL SOCIETY,,Bearing in H.NO: 4-167, SURVEY NO:189, Situated at MANIK BHANDAR (V), MAKLOOR(M), NIZAMABAD Dist./-Manik Bhandar/Makloor/Nizamabad
- The above said building was issued was issued No Objection certificate vide reference cited (2) for Non Multi storeyed Building with **1 Ground, 3 Floors**, with a height of **14.20** Meters for **EDUCATIONAL B-1 Schools up to senior secondary level** Occupancy .
- Now the Builder/Authorized person has requested to issue Renewal of No Objection Certificate for Occupancy to the Non Multi storeyed Building with **1 Ground, 3 Floors**, with a height of **14.20** Meters for **EDUCATIONAL B-1 Schools up to senior secondary level** Occupancy


4) Open Spaces:The builder provided the following open spaces all around the building.

Sl.No	Side	Open spaces as per Noc occupancy	Open spaces provided now
a 1	North	6.00	6.00
2	South	6.00	7.19
3	East	6.00	10.00
4	West	6.00	6.50
b Sl. No	Gate Width	As per Occupancy NOC	as per Noc occupancy provided now
1	Entry gate width	4.50	6.00
2	Entry Gate Head Clearance	5.00	6.00
3	Exit Gate Width	4.50	6.00
4	Exit Gate Head Clearance	5.00	6.00

5) Travel Distance

Sl.	Item / Description	as per Noc	provided
	<i>Seelo</i> <b>Correspondent</b> <b>Navyabharathi Global School</b> <b>Dasnagar, Nizamabad.</b>	<i>Anthy</i> <b>PRINCIPAL</b> <b>NAVYABHARATHI GLOBAL SCHOOL</b> <b>CBSE SENIOR SECONDARY SCHOOL</b> <b>AFFL. No. 3630071, SCHOOL No.: 57590</b> <b>NIZAMABAD-503003 (T.G), INDIA</b>	





**GOVERNMENT OF TELANGANA  
STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT**



No.		occupancy	now
1	Farthest point ( Most Remote Point) With in a storey or a mezzanine floor to the door to an Exit.	30.00	30.00
2	The Dead end of the corridor length in exit access. ( 6 mtrs for Educational, Institutional and Assembly, 15mtrs for other Occupancies)	6.00	6.00

6) Stair Cases (As per Occupancy NOC) :

Sl.no.	Type of staircases	Total width	No of staircases	Floors from	Floors to
1	Internal staircases	1.50	1	Ground	3rd Floor
2	External staircases	1.52	2	Ground	Terrace
3	External staircases	2.40	2	Ground	3rd Floor

7) Means of Escape Floor Wise Details :

Sl.no	Floor type	Buil-up Area in Sq.Mtrs	Type of Occupancy	Occupan t Load	Means of escape required as per Occupancy NOC	Means escape available now
1	Ground	1872.00	EDUCATIONAL B-1 Schools up to senior secondary level	468.00	9.34	9.34
2	1st Floor	1872.00	EDUCATIONAL B-1 Schools up to senior secondary level	468.00	9.34	9.34
3	2nd Floor	1872.00	EDUCATIONAL B-1 Schools up to senior secondary level	468.00	9.34	9.34
4	3rd Floor	1872.00	EDUCATIONAL B-1 Schools up to senior secondary level	468.00	9.34	9.34

8) Fire Shaft as per Occupancy NOC:

9) Floor Wise details of Fire Fighting Installations:

Sl.n o	Floor Details	Fire Extinguisher	Hose Reel	Automatic Sprinklers System	Manually Operated Electronic Fire Alarm System	Automatic detection and alarm system
1	Ground	10.00	4.00	0.00	0.00	0.00
2	1st Floor	10.00	4.00	0.00	0.00	0.00
3	2nd Floor	10.00	4.00	0.00	0.00	0.00
4	3rd Floor	10.00	4.00	0.00	0.00	0.00


10) Fire Fighting Installations As per Occupancy NOC :

Fire Fighting System.	Required As per Occupancy NOC	Provided
Fire Extinguishers	40	40
First Aid Hose Reel	8	16
Down Comer	4	4
Manually Operated Electronic Fire Alarm Systems	8	8
Capacity of Terrace Tank over Respective Tower Terrace in Litres	10000	30000
Pump capacity in LPM at the Terrace Tank level with min Pressure of 3.5 Kg/CM <sup>2</sup>	450	900

**Correspondent**  
**Navyabharathi Global School**  
**Dasnagar, Nizamabad.**

**PRINCIPAL**  
**NAVYABHARATHI GLOBAL SCHOOL**  
**CBSE SENIOR SECONDARY SCHOOL**  
**AFFL. No. 3630071, SCHOOL No.: 57590**  
**NIZAMABAD-503003 (T.G), INDIA.**





**GOVERNMENT OF TELANGANA  
STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT**



No. of Terrace Tanks over Respective Tower in ltrs	1	1
No. of Pumps at the Terrace Tank level with min pressure of 3.5 Kg/Cm <sup>2</sup>	1	1

11). The Non Multi storeyed Building Inspection Committee have reported that the Management has provided the Fire Safety Measures and there is no deficiencies.

**12. Remarks :**

As per the inspection report of Adfo and sfo renewal noc is approved.

13) In view of the above and as per recommendations of the Non Multi storeyed building inspection Committee, the Renewal of No Objection Certificate for occupancy is issued to Non Multi storeyed Building with **NAVYABHARATHI EDUCATIONAL SOCIETY,, Bearing in H.NO: 4-167, SURVEY NO:189, Situated at MANIK BHANDAR (V), MAKLOOR(M), NIZAMABAD Dist./-Manik Bhandar/Makloor/Nizamabad** with a height of **14.20 Meters** for **EDUCATIONAL B-1 Schools up to senior secondary level** Occupancy subject to the following conditions

Sl No	Builder and Management Body	Occupant	Management Body and fire and security personnel
1	-a) All the fire protection arrangements shall be maintained in good condition as seen during inspection. -b) Do's and Don'ts in case of fire shall be prominently displayed in entire building	All the escape/exit roots shall not be kept locked/blocked or encroached	All the occupants must know the correct method of operation of the fire fighting systems installed.
2	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibility of the management.	All occupants shall be trained to operate the fire safety equipment during emergency.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.
3	Addition / alteration, if any in the building may be verified by building authority.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.	All security personnel shall be trained to operate the fire safety equipment during emergency and guiding the occupants in safe evacuation. Call the fire Brigade by dialing 101.
4	This No objection Certificate for occupancy is valid for Five year from the date of issue of this letter.	Raise the alarm if the fire cannot be controlled, evacuate the area completely at once from the nearest safe exit.	Attack the fire using available fire equipment only if you feel capable of controlling it. If not, take all steps to isolate the area by closing doors and windows.


This Renewal of No Objection Certificate for Occupancy is valid for Five years from the date of issue of this letter. It is the responsibility of the builder to apply for renewal NOC, duly remitting the user charges as per G.O. Ms. No. 71, Home (Prison – A) Department, dated 01-04-2010, two months before expiry of this No Objection Certificate.

*[Signature]*  
**Correspondent**  
**Navyabharathi Global School**  
**Dasnagar, Nizamabad.**

*[Signature]*  
**PRINCIPAL**  
**NAVYABHARATHI GLOBAL SCHOOL**  
**CBSE SENIOR/SECONDARY SCHOOL**  
**AFFL. No. 3630071, SCHOOL No.: 57590**  
**NIZAMABAD-503003 (T.G), INDIA.**

Signed By : G.Murali Manohar Reddy  
Designation : District Fire Officer , Nizamabad  
Date : 09-03-2024  
District fire officer,  
Nizamabad Division.





**GOVERNMENT OF TELANGANA  
STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT**



"THIS IS COMPUTER GENERATED DOCUMENT AND DO NOT REQUIRE ANY STAMP OR SIGNATURE"  
Copies to:

- i) The Management
- ii) Non Multi storeyed Building Inspection Committee
- iii) Copy submitted to Regional Fire officer
- iv) Copy submitted to DG fire services

*[Signature]*  
**Correspondent  
Navyabharathi Global School  
Dasnagar, Nizamabad.**

*[Signature]*  
**PRINCIPAL  
NAVYABHARATHI GLOBAL SCHOOL  
CBSE SENIOR SECONDARY SCHOOL  
AFFL. No. 3630071, SCHOOL No.: 57590  
NIZAMABAD-503003 (T.G), INDIA.**